



## TENT INSPECTIONS CHECKLIST

**1015 Second Ave. S North Myrtle Beach, SC 29582**

**Phone: 843-280-5614 Fax: 843-280-5617**

| Administration & Permits Code                      | Code Ref.   | YES | NO |
|--|-------------|-----|----|
| Construction Documents Submitted & Approved        | 3103.6      |     |    |
| All Operational Permit(s)                          | 105.6.45    |     |    |
| Use Requirements Code                              |             |     |    |
| Adequate Fire Apparatus Access Provided 20 ft.     | 503         |     |    |
| Adequate Placement of Tent(s) 20 Ft.               | 3103.8.2    |     |    |
| Tents 15,000sf > not Less than 50ft. to Structures | 3103.8.3    |     |    |
| Tents with Connecting Corridors                    | 3103.8.5    |     |    |
| 12ft. Unobstructed Fire Break Provided             | 3103.8.6    |     |    |
| Tents Adequately Braced & Anchored                 | 3103.9      |     |    |
| Seating Plan Required & Approved                   | 3103.11     |     |    |
| Exits provided per occupant load                   | 3103.12     |     |    |
| Occupant Load Posted if Assembly                   | CHP 10      |     |    |
| Exit Doors Swing in Direction of Egress            | 3103.12.4   |     |    |
| Aisle Widths Maintained                            | 3103.12.5   |     |    |
| Exit Signs Provided, Two Sources if >300 Occupants | 3103.12.6.1 |     |    |
| Means of Egress Maintained                         | 3103.12.8   |     |    |
| Fire Retardant Certificates on Tent/Contents       | 3104.2      |     |    |
| Improper Use of Combustible Materials              | 3104.5      |     |    |
| No Smoking Signs Posted                            | 3104.6      |     |    |
| No Open Flame Devices Used in or Within 20ft.      | 3104.7      |     |    |
| Fire Extinguishers/Fire Protection Provided        | 906         |     |    |
| Approved Heating & Cooking Equipment               | 3104.15     |     |    |
| Heating/Cooking Equip. 10' of Exits & Combustibles | 3104.15.3   |     |    |
| Approved Use of Butanes for Warming Foods          | 3104.15.4   |     |    |
| Cooking Tents Separated by 20 ft.                  | 3104.15.5   |     |    |
| Outdoor Cooking Not Within 20 ft.                  | 3104.15.6   |     |    |

|  |             |  |  |
|--|-------------|--|--|
| Approved LP Gas Equipment                        | 3104.16.1   |  |  |
| LP containers less than 500 gal. 10ft. Away      | 3104.16.2.1 |  |  |
| LP Gas Containers More Than 500 gal. 20 ft.      | 3104.16.2.2 |  |  |
| LP Gas Equipment Protection/Security             | 3104.16.3   |  |  |
| No Flammable Liquid Equipment in Tents           | 3104.17     |  |  |
| Flammable Liquids Stored 50ft. From Tents        | 3104.17.2   |  |  |
| No Refueling Within 20ft. of Tents               | 3104.17.3   |  |  |
| Generators Separated from Tents by 20ft.         | 3104.19     |  |  |
| Fire watch - Standby Personnel Required          | 3104.2      |  |  |
| Combustible Vegetation Removed From Within 30ft. | 3104.21     |  |  |
| <b>Vehicles on Display</b>                       |             |  |  |
| Batteries disconnected                           | 3104.18.1   |  |  |
| No fueling or re-fueling                         | 3104.17.3   |  |  |
| Maximum fuel tank level                          | 3104.18.2.1 |  |  |
| No fuel system leaks                             | 3104.18.2.2 |  |  |
| Tank opening locked and sealed                   | 3104.18.2.3 |  |  |
| Vehicles shall not obstruct exits                | 3104.18.3   |  |  |
| CNG or LP gas vehicles inside assembly tents     | 3104.18.4   |  |  |
| Fuel storage for demos or competitions/outside   | 3104.18.5   |  |  |
| Fuel spills for demos or competitions./outside   | 3104.18.5   |  |  |
| <b>Air Supported Structures</b>                  |             |  |  |
| Proper anchoring                                 | 3103.9      |  |  |
| Min. 2 blowers provided                          | 3103.10.3   |  |  |
| Auxiliary power for Assembly use over 200 people | 3103.10.4   |  |  |